

# SEVIERVILLE EVENTS CENTER @ BRIDGEMONT

## UTILITY SERVICES

### EXHIBIT HALL FLOOR BOXES

- Power
- \* One (1) 60 amp, 120/208, 3 phase, 5 wire, pin & sleeve outlet
  - \* Two (2) 20 amp, 120V duplex GFI receptacles
  - \* Four (4) 20 amp, 120V standard duplex receptacles
- Communications
- \* Empty 4" PVC conduits connecting floor box to all adjacent boxes

### EXHIBIT HALL COLUMNS

- Compressed Air
- \* Compressed air outlets at all columns
- Water
- \* One (1) 3/4" cold water line with a hose bid connection at 54" above floor at all columns
- Power
- \* One (1) 20 amp 120V quad receptacle at each column
- Communications
- \* One (1) quad box for telecommunications

### EXHIBIT HALL INTERIOR WALLS

- Power
- \* At two (2) locations a 400 amp, 480V circuit with disconnect switch to be used for sound/lighting and other systems

### BALLROOMS

- Power/  
Communications
- \* Eight (8) power/data floor boxes spaced approximately 50' on center each contains two (2) 20 amp, 120V receptacles and two (2) blank communications compartments. A 1 – 1/4" conduit is routed to facility cable tray
  - \* 20 amp, 120V quad receptacles with an accompanying voice/data outlet are located on 40' centers around the perimeter of the room

### MEETING ROOMS

- Power/  
Communications
- \* Two (2) power/data floor boxes per room for voice/data/cable TV
  - \* 20 amp, 120V convenience receptacles are provided

## CONCOURSE/ PRE- FUNCTION AREAS

Water/drain \* Floor drains spaced 30' on center throughout one side of the concourse

Power/

Communications

\* 30 amp, 120/208V, 3-phase, 5 – wire, outlets spaced 15' on center

\* 20 amp, 120V duplex GFI receptacles spaced periodically.

\* 20 amp, 120V quad receptacles and voice data outlets spaced 30' on center